
**Exam : ISA-IEC 62443 Cybersecurity
Maintenance Specialist**

**Title : ISA-IEC 62443
Cybersecurity Maintenance
Specialist**

Version : DEMO

1.What should be included in the forensics portion of an incident response plan?

- A. A high-level risk assessment
- B. The recommended forensic tool vendor list
- C. The designated point of contact for outside media
- D. Directives to consider the skill level of personnel who accessed the system

Answer: D

2.Which is a characteristic of incident response planning policies and procedures?

- A. Virtual
- B. Colorful
- C. Detailed
- D. Password-protected

Answer: C

3.Which statement BEST describes the Four “Ts” of Managing Risk?

- A. A set of rules to ensure risks are always insured
- B. A framework to increase risk exposure for testing
- C. A mandate to eliminate all organizational risk entirely
- D. A set of techniques to accept, pass, stop, or reduce risk

Answer: D

4.Which should be performed during post-incident analysis and forensics?

- A. Network traffic capture
- B. High-level gap assessment
- C. Active vulnerability testing
- D. Penetration testing

Answer: A

5.Which step is an element of log analysis during post-incident analysis and forensics?

- A. Identify IACS systems architecture and components.
- B. Plan, implement, and evaluate changes to the IACS.
- C. Determine applicability of software patches to the IACS.
- D. Compare running IACS configuration to a last known good configuration.

Answer: D